

ELECTRIC POWER CORPORATION

Level 5
TATTE Building
Sogi
Apia
Samoa



Telephone: (685) 65 500
Facsimile: (685) 23 748
E-mail: epc.info@epc.ws
Website: www.epc.ws
PO Box: 2011

April 13, 2026

Dear BIDDERS

Subject: Procurement of Solar & UPS Systems Bid – SAMEPC 06/2026

Addendum No. 1

This Addendum No 1 clarifies and answers queries from some of the bidders for the above tender.

1. The EPC accepts alternative solar panel configuration such as 3 x 490W.
2. All systems installations are indoors
3. Racks/Cabinets are not required
4. The Automatic Transfer Switch (ATS) must be fully automatic
5. The EPC accepts 48V 100AH Lithium Battery as alternative to the 48V 110Ah Battery.
6. For the solar system, please include wires for the system and roof mount for the panels

Sincerely

A handwritten signature in blue ink, appearing to read 'Asolima Leapai', is positioned above the typed name.

Asolima Leapai
EPC Telecom Engineer
NCC, EPC

Copy: Chief Engineer NCC